

# Certificate of Compliance

Certificate Number **20080613-EX15026**  
Report Reference **EX15026, 2006 March 30**  
Issue Date **2008 June 13**

Page 1 of 2



*Issued to:* **COMPUTRONIC CONTROLS LTD**  
41-46 RAILWAY TERR, NEHELLS  
BIRMINGHAM, B7 5NG UNITED KINGDOM


*This is to certify that representative samples of* **COMPONENT - BATTERY CHARGERS FOR USE WITH INTERNAL COMBUSTION ENGINE DRIVING CENTRIFUGAL FIRE PUMPS**  
Models Guardian G150 12, G300 12, G300 24 and G600 24

*Have been investigated by Underwriters Laboratories Inc.® in accordance with the Standard(s) indicated on this Certificate.*

*Standard(s) for Safety:* **UL 1236 - Battery Chargers for Charging Engine -Starter Batteries - Seventh Edition**

*Additional Information:* **See Addendum for Electrical Ratings**

**Only those products bearing the UL Recognized Component Marking should be considered as being covered by UL's Recognition and Follow-Up Service.**

The UL Recognized Component Marking generally consists of the manufacturer's identification and catalog number, model number or other product designation as specified under "Marking" for the particular Recognition as published in the appropriate UL Directory. As a supplementary means of identifying products that have been produced under UL's Component Recognition Program, UL's Recognized Component Mark:  may be used in conjunction with the required Recognized Markings. The Recognized Component Mark is required when specified in the UL Directory preceding the recognitions or under "Markings" for the individual recognitions.

**Look for the UL Recognized Component Marking on the product**

Issued By:  
**Wondwossen Alemayehu, Project Engineer**  
Underwriters Laboratories Inc.

Reviewed By:  
**Ronald C. Hagen, Senior Staff Engineering Associate**  
Underwriters Laboratories Inc.

# Certificate of Compliance

Certificate Number **20080613-EX15026**  
Report Reference **EX15026, 2006 March 30**  
Issue Date **2008 June 13**

Page 2 of 2



This is to verify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

## ELECTRICAL RATING:

Model	Input			Output, dc	
	V	A	Hz	V	A
G150 12	120 / 240	2.4/1.2	50/60	12	10
G300 12	120 / 240	4.8/2.4	50/60	12	20
G300 24	120 / 240	4.8/2.4	50/60	24	10
G600 24	120 / 240	10.5/5.25	50/60	24	20

Issued By:  
**Wondwossen Alemayehu, Project Engineer**  
Underwriters Laboratories Inc.

Reviewed By:  
**Ronald C. Hagen, Senior Staff Engineering Associate**  
Underwriters Laboratories Inc.